

Circuit Breaker HGG HGG1B125L Certification acc.
UL489 1 Pole; Rated current IN=125A max. voltage
347V AC NEMA rating 35kA @ 277V NEMA rating 22kA
@ 347V line and load lugs included

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

<http://www.siemens.de/industrial-controls/catalogs>

Industry Mall (Online ordering system)

<https://mall.industry.siemens.com>