

Circuit Breaker SENTRON Type SCND
SCND6A120LSIG Certification acc. UL489 3 Pole Rated
current IN=1200A NEMA rating 65 kA @ 600V NEMA
rating 100KA @ 480V 100% Rated electronic trip unit,
LSIG

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

<http://www.siemens.de/industrial-controls/catalogs>

Industry Mall (Online ordering system)

<https://mall.industry.siemens.com>