

Circuit Breaker SENTRON Type SND SND6B100LSIH
Certification acc. UL489 3 Pole Rated current IN=1000A
NEMA rating 25 kA @ 600V NEMA rating 50KA @ 480V
100% Rated electronic trip unit, LSIH

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

<http://www.siemens.de/industrial-controls/catalogs>

Industry Mall (Online ordering system)

<https://mall.industry.siemens.com>