

Circuit Breaker SENTRON Type SND SND6B800LSIH  
Certification acc. UL489 3 Pole Rated current IN=800A  
NEMA rating 25 kA @ 600V NEMA rating 50KA @ 480V  
100% Rated electronic trip unit, LSIH

## Further information

**Information- and Downloadcenter (Catalogs, Brochures,...)**

<http://www.siemens.de/industrial-controls/catalogs>

**Industry Mall (Online ordering system)**

<https://mall.industry.siemens.com>